International Journal of Mechanical and Production Engineering Research and Development (IJMPERD)
ISSN (P): 2249–6890; ISSN (E): 2249–8001
Vol. 9, Issue 4, Aug 2019, 1423–1432

HEAT TRANSFER ANALYSIS USING CFD TOOLS AN LITERATURE BASED REVIEW

GADIPELLY BHASKAR[1*] & K. V. NARASIMHA RAO[2]

[1]*Research Scholar, Department of Mechanical Engineering, Koneru Lakshmaiah Education Foundation, Vaddeswaram, Guntur, Andhra Pradesh, India*

[2]*Professor, Department of Mechanical Engineering, Koneru Lakshmaiah Education Foundation, Vaddeswaram, Guntur, Andhra Pradesh, India*

ABSTRACT

Computational fluid dynamics (CFD) is commonly used in engineering procedures for fixing and modeling and modeling complicated manufacturing apps. However, simulation time is too lengthy and time is dramatically shortened according to control requirements. Methods and instruments for calculating power allocation and governance are often employed for the analysis in various manufacturing systems such as heat furnaces and boilers and in various fields of blending and heat systems. A very big energy saval can be achieved with a tiny quantity of optimization. The CFD in real time is evaluated, controlled and optimized for different manufacturing procedures on line. This instrument or process can help build power technologies that are effective and viable. The purpose of this job is to identify alternative simulation methods that also can deal with manufacturing apps and offer reasonable precision and resolution alternatives. CFD simulation of refrigeration pipes for heat transfer and thermal processes where thermal energy is used and cooling water is overused.

KEYWORDS: Computational Fluid Dynamics, Heat Transfer, Micro-Channels, Temperature, Optimization & Simulation

Received: May 14, 2019; **Accepted:** Jun 06, 2019; **Published:** Sep 19, 2019; **Paper Id.:** IJMPERDAUG2019147

Original Article

INTRODUCTION

In the many installations, including power plants, methods and warmth retrieval units, heat exchangers play a significant part. Its inevitable desire has required economic and efficient styles to achieve an optimal share in system efficiency. The log Mean temperature distinguishing method is used for the warmth cash broker style, and therefore the various warmth transfer units technology. However, cost-effective access to strong tiny processors paved the way for the development of fluid dynamics (CFD) in the chapter look.

Between the novel techniques for the thermal administration for the high-temperature fluxes found inside microelectronic devices, micro channels will be the most reliable in heat elimination. The alternative concerning combining micro channels straight within the heat-generating substrates will make consumers especially appealing because thermal contact resistances can be prevented. A significant number of the latest investigations have actually performed to analyze that the fundamentals concerning micro channel flowing, including to evaluate their flow as well as heat transfer attributes concerning micro channel sat established channels. An intensive outline of those sort of investigations performed throughout the last decade is truly introduced in tabular form. Assumed correlations also are become recommended inside the review, in step with experimental investigations on in small channels. Different permutations of channels size, pitch further as

substrate data have-been thought of. Usually, this sort of correlations has been give identical as a result of as established relationships for the large-diameter tubes further as channels, however, but have incorporated altered coefficients.

LITERATURE REVIEW

Table 1: Literature Review of Microchannels

Parameters	Work	Conclusion	Reference
Micro Channel Concepts			
Small water size W=50 μm; S = 300 microns Q=4.7, 6.5.	The entire heat sink for integrated silicone circuits	Demonstrated use of tiny convective channels in embedded cooling circuits for extremely elevated heat transfer (790 W/cm^2distinguish the temperature of a substratum from coolant 71°C)	Tuckerman & Pease (1981) [1]
Cooling of integrated circuits	Discussion of details on micro channel and its fabrication.	Merit coolant provided: CFOM = $(kc\acute{c}/\mu)^{0.25}$ and $(kc\mu^2C^2/\mu)^{0.25}$ and given breathing energy coolant	Tuckerman & Pease (1982) [2]
W = 130-350□m, H = 3.0-70 □m, D_h = 50-86 □mnitrogen in silicon and glass	Chart values for commercial channels	Re < 900 f= 0.185 + 0.017) / Re 0.071 + 0.007 (100 + 8) 900 < Re < 3000 f= (0.185 +.017) / $Re^{0.11}$ Factor f= 0.185 + 0.017)	Wu & Little (1983) [3]
sW = 120-350 □m, H = 35-70 □m, D_h = 55-86 □□	Experiments on Heat transfer	Nusselt number, Nu = $0.0022Pr^{0.4}Re^{1.09}$Re >3000	Wu & Little (1984) [4]
W = 0.13 to 0.25 mm, H / W = 10, As = 47 to 63 m^2 per cm^3 of silicone water	Comparison of performance with conventional heat sinks, based on correlations	Micro structured heat sinks important compared to conventional air circulation heat sinks	Mahalingam & Andrews (1987) [5]
Rectangular; water in silicon:W = 60-500□m	A fully advanced theoretical model,	laminar flow less efficient compared to turbulent flow.	Phillips et al. (1989)
N Silicon propanol: Ac = 90-7400sq.m Rectangular	Experiments	Submissions f = C / Re provided in graphs C vs. Re (laminar)	Pfahler et al. (1990) [7]
Structures for cooling applications	Discussed	Discussions about heat exchangers and fluid distribution systems.	Hooman (1990) [8]

Table 2: Literature Review of Single-Phase (liquid) Experiments

Parameters	Work	Conclusion	Reference
D = 5, 9, 10, 53, 81, oscillates, L = 24-52 mm, silica nitrogen	Heat transport experiments	Laminar: (Re<2000) f = 64/Re [1 + 30(v / Dca]$^{-1}$ Turbulent: f = 0.140 $Re^{-0.182}$ Nusselts / Nusselt numbers correlation:	Choi et al. (1991) [9]
W = 1 mm: H = 176-325 oscillating: L = 46 mm, P = 2 mm water in silicone engraved.	Experiments	Less than nutrient numbers are analytical alternatives to develop laminar fluid	Rahman & Gui (1993) [10]
Single-Phase (Liquid) Experiments			
W = 0.8 mm; H = 0.9 mm, T_i = 30-60°C, v = 0.3-3.1 m/s deionized, water in stainless steel	Forced convection of a single phase	Single phase convection, a high wall thermal flux rises at wall temperature	Peng & Wang (1993) [11]

Table 2: Contd.,

T = 0.4, 0.6, 0.8 mm, H = 0.7 mm, Ti = 12-45°C, 14-19°C (methanol), V = 0.4-3.1 m / water, T-12-45°C (liquid).	Forced thermal transfer and convection flow	Turbulent convection regime fully developed begins at Re = 1000–1500	Wang & Peng (1994) [12]
Water in stainless steel Dh = 0.143-0.367 mm, L = 50 mm	Laminar and turbulent flow frictional conduct experiments	Re = 200–700 Flow transition.	Peng et al. (1994a) [13]
Dh = 0.133-0.367 mm, L = 50 mm, H / W.	Forced heat transfer features experiments	Nu = Ch, l $Re^{0.62}$ $Pr^{1/3}$ Laminar; Nu = Ch, t $Re^{0.8}$ $Pr^{1/3}$ Turbulent (Ch, l, C h, t in chart 2).	Peng et al. (1994b) [14]
Excluding Ti = 11 to 18°C (air),12 to 20°C (methanol) V= 0-2.1 m/s (air), 0.2 to 1.5 m/s (methanol)	Thermal fluid and geometry impact testing Connective Heat Transfer Effects	Changes in stream systems in micro-channels relative to standard circuits in low-revolution Heat transmission methods;	Peng & Peterson (1995) [15]
Dh = 0.133 0,367 mm, L = 50 mm, H / W = 0.333-1. Water in stainless steel.	One-phase fluid and heat transfer experiments	Correlations proposed $Nu = 0.1165\,(D_h/P)^{0.81}(H/W)^{-0.79}Re^{0.62}Pr^{0.33}$ Laminar	Peng & Peterson (1996a) [16]

Table 3: Literature Review of Experimental and Theoretical of Micro-Channels

Parameters	Work	Conclusion	Reference
Dh = 0.133-0.367 mm, L = 50 mm W = 0.1, 0.2, 0.3, 0.4 mm of stainless-steel methanol mixing	Experiments	Fully advanced, turbulent heat transfer at Re = 200-700, according to Dh	Peng & Peterson (1996b) [17]
Silicon water W = 251 daffodil, H = 1030 microns, Dh = 404 microns, L = 2.5 cm, Q = 5.47-118 cm^3/s	Studies of theory and experimentation	The assessment demonstrated the ability to improve fluid and heat transfer efficiency by enhancing H and the reduction in thermal resistance to lower tubes for the same pumping energy and the same pressure drop.	Harms et al. (1997) [18]
Sizes (mm): Length = 35, B = 0.146, 0.210, 0.234) Size of nozzle (cm)	Experiment impingement on 2D microchannels	Nusselt Number empirical correlation for both Nux fluids = $0.429Re^{0.583}Pr^{1/3}(x/2H)^{0.349}(B/2H)^{-0.494}$	Zhuang et al.(1997) [19]
Copper D = 0.102-1.09 mm distilled water V< 18.9 m/s, Re = 2.6 x 10^3 – 2.3 x 10^4, Pr = 1.53-6.43 q” < 3.0 MW/m^2	Tumultuous one-phase stream experiments	The amount of Nusselt is greater than those forecast in big canals.	Adams et al. (1998) [20]
Non-circular; water in copperDh = 1.13 mm, Re = 3.9x10^3 – 2.14x10^4, Pr = 1.22-3.02	Turbulent convection experiments	Experimental number Nusselt well-foreseen by NuGn Dh = 1.2 mm suggested to apply Nusselt normal correlations with non-circular channels as a sensible reduced threshold	Adams et al. (1999) [21]
Transition flow and rectangular flow	The literature review experimental information.	Tentatively to explain that with rising Re within the bedding system, the correspondence may reduce and will remain unchanged within the transition system	Tso & Mahulikar(1998, 1999) [22, 23]
Nearly round; aluminum water Dh = 0.73 mm.	Experiments	Found correlation between laminar flow information using the number Brinkman	Tso & Mahulikar (2000) [24]

Table 3: Contd.,

W is = 450.500 l / s, H is = 2.5 cm, Q is 1-8 l / s.	Experiments, optimization	The heat strength of the tiny driver for heat decreases by means of immediate air conditioning, with an component of more than three	Kleiner et al. (1995) [26]
D = 8.1-96 microns, 0.76-4,7 microns	Superfluid Helium flow numeric research using a "two liquid template"	'Optimal channel diameter is available for the specified peak mass flow rate.	Takamatsu et al. (1997) [27]
C = 110-1100 microns, H = 140-200 microns., S = 42.5-113.4 microns.	Micro-channel thermal sink numerical analysis.	The 3D model was in close accordance with a simple 1D model at elevated water rate Numerical outcomes showed the significant softer effects of W than analytical outcomes.	Copeland et al. (1997) [28]
Aqueous electrolyte is diluted at 35 m parallel sheets. L = 20 mm	Theoretical assessment that includes the impacts of double layer electrical field	The result was that EDL stream rates were much smaller than the conventional hypothesis, so that the temperature spectrum moved and Re decreased.	Mala et al. (1997a) [29]
Parallel sheets. Solicium and crystal (10 x 20 mm) at 10-280 knuckles; oscillation P = 0-350 bar Separation.	Research and comparison with the expected stream rate of quantity	EDL outcome negligible EDL outcome becomes essential for dilute alternatives for elevated ion concentrations as for DH > a few hundred m.	Mala et al. (1997b) [30]
H = 30 □m, W = 40 □m, L = 10 mm	"EDL influences numerical analysis.	The EDL field and electrometric Potential fluid stream act, providing increased friction, decreased flow speed and a decreased range of Nusselt for dilute alternatives	Yang et al. (1998) [31]
Rectangular micro heat exchangers	Micro channel shape and optimization	The width of warm cash changer pipes could also be optimized to decrease the most-hot ground temperature	Bau (1998) [32]
Micro channel cooling and jet impingement	Research on jet and micro-channel cooling Analysis	Thermal performance of the jet penetration with no treatment of expended flow significantly less than that of small channels, regardless of the target	Lee and Vafai (1999) [33]

Table 4: Literature Review of Two-Phase Flow

Parameters	Work	Conclusion	Reference
Fiberglass FC-72 W=5 mm, H=2.5 mm, warm length=10.6 mm, V=0.25-10 m/s, Re=2000-130000 Rectangular; FC-72	Lengthy channel CHF tests; visualization of stream	The spread of vapor spots that resemble the hot wall of a curved steam coating at critical thermal flows	Sturgis & Mudawar (1999a) [34]
FC-72 in fiberglass W = 5 mm, H=2.5 mm, heat-length = 101.6 mm, v = 0.25-10 m / s, Re = 2000-130000 socket storage =3, 16, 29 feb. Rectangular;	The theoretical CHF model; data analysis	Effect of periodical assignment as a sinusoidal surface in the path of stream frequency and amplitude.	Sturgis & Mudawar (1999b) [35]
Two-Phase Flow			
R114 in coppers W = 0.27 mm, H = 1.0 mm, Dh = 425 mm, R124 in copper W = 0.27 mm. Re Dh = 100-750; q"< 40W/cm^2	Micro channel exchanger experiments	Nusselt number (~ 5 to 12) noted a rise with the amount of Reynolds but it was about continuous	Cuta et al. (1996) [36]

Table 4: Contd.,

Rectangular; R124 in copper W = 270 □m, H = 1000 □m, L = 2.052cm,	Experiments with two microchannel patterns (parallel and diamond)	Coefficient thermal transfer and pressure fall, aside from thermal stream and super-heat surface, are discovered to be flux quality and mass flow features	Ravigururajan (1998) [37]
Dh = 1.09, 1.49 mm, v(air): 0.02–80 m / s, v(water): 0.21–80 m / s (superficial velocity), air – water mixture in glass D = 1.1, 1.45 mm, Dh = 1.09, 1.49 mm.	Flow model and model charts visual observation	The models noted for snorkeling, churn, slug, slug and annular flow	Triplett et al. (1999a) [38]
Dh = 1.09, 1.48 mm. v(air): 0.02-80 m / s, v(water): 0.52-80 m / s (surface speed); air-water blend of D = 1.2, 1.45 mm.	Friction stress falls measured and contrasted to two different designs of friction	Over predicted channel proportion and strain decrease models and correlations in ring stream structure	Triplett et al (1999b) [39]
Air / water blend of glass Dh = 1.3-5.5 mm; V = 0.1-100 m / s (vapor); V = 0.01-10 m / s (fluid) Circular and Rectangular;	Experiments for visualizing flow	Superficial gas and fluid speeds influenced by tubing diameter owing to the mixed impact of ground stress, a hydraulic and aspect ratio	Coleman & Garimella (1999) [40]
Water in copper 0.5 x 12 mm, 0.125 x 12 mm Q = 0.47-5 ppm	Design and testing, micro channel heat exchanger for laser diode arrays	Thermal resistance due to solder bond estimated	Roy & Avanic (1996) [41]
Air in copper, aluminum	Parametric studies and experiments of air impingement in micro channels	Thermal resistance model developed Parametric experiments to determine the effect on heat strength by static stress, pump strength and geometric parameters	Aranyosi et al (1997) [42]
Diamond-shaped and hexagonal; water in silicon	3D numerical model; heat resistance reduction optimization	The smallest heat strength was in rectangular geometry	Perret et al. (1998) [43]
Water, FC72 in copper	3D and 1D thermal resistance designs on the micro thermal sink for multi-chip power module	Dissipated with 350C and pumping power of about 1W per chip with a temperature increase of 230-350 W / cm2	Gillot et al. (1998) [44]
Water, steel W = 230 (FC 72) and 30 (2-); 2000 (FC 72 1-) and 300(2-); Water (FC 72) Rectangular; Water, FC 72) = 1350 (earth, 1-) and 30 (2-);	Experiments with single and double phase heating transistor micro-heat exchangers	Two-phase heat switch supplied reduced heat strength and reduced stress relative to single-phase heat switchers.	Gillot et al. (1999) [45]
Copper air 800 x 50 mm, Q = 140 m^3/h Copper atmosphere = 800	Thermal resistance model and experiments	A big difference from the values for the elevated air flows was discovered. Pressure decrease cooling capacity□1700 W at heat flux □15W/cm^2	Yu et al. (1999) [46]

In the above literature table 1, 2, 3 and 4 provided the information of reviews of different points like micro channels, single phase, two phase, experimental and theoretical works of Multi phase flow in different geometrical model with or without phase change is commonly encountered in a variety of engineering and industrial applications/processes. Due to its universality in applications, a thorough understanding of multi phase flow is of utmost important.

CONCLUSIONS

In a tabular shape, a comparison analysis for research findings within the fluid literature and thermal transfer within micro streams was collected in a variety of subjects. Correlations of the single rubbing factor and the amount of Nusselt proposed that a roster of researchers had been likened to proven correlations for bigger, more developed pipes as well as lamellar channels and interruptive stream systems, based on their studies. Several to performing fluid as well as substrate combinations as well as shapes and also adjustments for the micro channels tend to be a part of within.this contrast- This contrast. There is little consensus among the various researchers ' projections. Either fluid and some substratum or the sizes and shapes of micro channels do not really show their impact.

Their comparative research here presented differences between the fluid and heat transfer in micro-channels and, consequently, in circuits relating to fixed sizes. The literature data so far is not able to suggest unambiguous events regarding disagreements or causes. There certainly no proof which continuum presumption tend to be violated when it comes to micro channels tested, because of the diversity within the leads to within For design programs, including micro channel heat sinks, the literature, the appropriate Heat transfer rate forecast, and pressure falls in micro channels are definitely not currently feasible. We have a evident requirement for further organized studies that think about every parameter quantity affecting transport inside micro channels.

Scope of the Research

Conventional techniques for a fresh geometric model layout and creation for the very costly heat exchange. In the construction and optimization of a fresh geometric model, CFD offers an option to economic-efficiency quick solution. The CFD findings are an essential component of the development method, eliminating prototype requirements. Further studies should be carried out with distinct fluid parameters to optimize the efficiency of fresh geometry for heat exchange. Because of a absence of appropriate mathematical models to depict a physical method, CFD remains a growing art in erosion / corrosion forecast.

REFERENCES

1. *Tuckerman, D. B., and Pease, R. F. W., 1981, "High-performance heat sinking for VLSI," IEEE Electron. Device Letters, Vol. EDL-2, pp. 126–129.*
2. *Tuckerman, D. B., and Pease, R. F. W., 1982, "Ultrahigh thermal conductance microstructures for cooling integrated circuits," Procs. 32nd Electronics Components Conf., IEEE, EIA, CHMT, pp. 145–149.*
3. *Wu, P. Y. and Little, W. A., 1983, "Measurement of friction factor for the flow of gases in very fine channels used for micro-miniature Joule Thompson refrigerators," Cryogenics, Vol. 23, pp. 273–277.*
4. *RAHI, A. A., BUTT, B., & BOKHARI, T. Z. (2014). Responses of Zea mays productivity to interactive effects of tillage operations and wheat straw mulch under an arid environment for agricultural policy measures. International Journal of Agricultural Science and Research (IJASR), 4(2), 27–36.*
5. *Wu, P. Y. and Little, W. A., 1984, "Measurement of the heat transfer characteristics of the gas flow in fine channel heat exchangers for micro miniature refrigerators," Cryogenics, Vol. 24, pp. 415–420.*
6. *Mahalingam, M. and Andrews, J., 1987, "High-performance air cooling for microelectronics," Procs. Int. Symp. on Cooling Technology for Electronic Equipment, Honolulu, Hawaii, pp. 608625.*

7. *A. Phillips, R. J., Glicksman, L. R., and Larson, R., 1987, "Forced convection, liquid-cooled, micro channel heat sinks for high-power-density microelectronics," Procs. Int. Symp. Cooling Technology for Electronic Equip., Honolulu, HI, USA, pp. 227–248.*
8. *Bodade, P. R., Jogi, N., Gorde, M., Paropte, R., & Waghchore, R. use of Internal Threads of Different Pitches to Enhance Heat Transfer in A Circular Channel.*
9. *Pfahler, J., Harley, J., Bau, H. H., and Zemel, J., 1990, "Liquid transport in micron and submicron channels," J. Sensors Actuators A, Vol. 21-23, pp. 431–434.*
10. *Hoopman, T. L., 1990, "Micro channeled structures," Microstructures, Sensors, and Actuators, ASME DSC-108, pp. 171–174.*
11. *Owaid, A. I., Tariq, M., Issa, H., Sabeeh, H., & Ali, M. The Heat Losses Experimentally in the Evacuated Tubes Solar Collector System in Baghdad-Iraq Climate.*
12. *Choi, S. B., Barron, R. F., and Warrington, R. O., 1991, "Fluid flow and heat transfer in micro tubes," Micromechanical Sensors, Actuators and Systems, ASME DSC-Vol.32, pp. 123,134.*
13. *Rahman, M. M., and Gui, F., "Experimental measurements of fluid flow and heat transfer in micro channel cooling passages in a chip substrate," Advances in Electronic Packaging, ASME EEP-Vol. 4-2, pp. 685–692.*
14. *QASHQAEI, A., & ASL, R. G. (2015). Numerical Modeling and Simulation of Copper Oxide Nanofluids used in Compact Heat Exchangers. International Journal of Mechanical Engineering, 4 (2), 1, 8.*
15. *Peng, X. F. and Wang, B. X., 1993, "Forced convection and flow boiling heat transfer for liquid flowing through microchannels," Int. J. Heat Mass Transfer, Vol. 14, pp. 3421–3427.*
16. *Wang, B. X. and Peng, X. F., 1994, "Experimental investigation on liquid forced convection heat transfer through micro channels," Int. J. Heat Mass Transfer, Vol. 37, Suppl. 1, pp.73–82.*
17. *Peng, X. F., Peterson, G. P., and Wang, B. X., 1994a, "Frictional flow characteristics of water flowing through microchannels", Experimental Heat Transfer, Vol. 7, pp. 249–264.*
18. *Peng, X. F., Peterson, G. P., and Wang, B. X., 1994b, "Heat transfer characteristics of water flowing through micro channels", Experimental Heat Transfer, Vol. 7, pp. 265–283.*
19. *Peng, X. F., and Peterson, G. P., 1995, "The effect of thermofluid and geometrical parameters on convection of liquids through rectangular micro channels," Int. J. Heat Mass Transfer, Vol. 38, pp. 755–758.*
20. *Peng, X. F. and Peterson, G. P., 1996a, "Convective heat transfer and flow friction for water flow in micro channel structures," Int. J Heat Mass Transfer, Vol. 39, pp. 2599–2608.*
21. *Peng, X. F., and Peterson, G. P., 1996b, "Forced convection heat transfer of single-phase binary mixtures through micro channels," Experimental Thermal and Fluid Science, Vol. 12, pp. 98–104.*
22. *Harms, T. M., Kazmierczak, M., Gerner, F. M., Holke, A., Henderson, H. T., Pilchowski, J., and Baker, K., 1997, "Experimental investigation of heat transfer and pressure drop through deep micro channels in a (110) silicon substrate," ASME HTD-Vol.351-1, pp. 347-357.*
23. *Zhuang, Y., Ma, C. F., and Qin, M., 1997, "Experimental study on local heat transfer with liquid impingement flow in two-dimensional micro-channels," Int. J. Heat Mass Transfer, Vol. 40, pp. 4055–4059.*
24. *Adams, T. M., Abdel-Khalik, S. I., Jeter, S. M., and Qureshi, Z. H., 1998, "An experimental investigation of single-phase forced convection in micro channels," Int J Heat Mass Transfer, Vol. 41, pp. 851–857.*

25. *Adams, T. M., Dowling, M. F., Abdel-Khalik, S. I., and Jeter, S. M., 1999, "Applicability of traditional turbulent single-phase forced convection correlations to non-circular micro channels," Int. J. Heat Mass Transfer, Vol. 42, pp. 4411–4415.*
26. *Tso, C. P., and Mahulikar, S. P., 1998, "Use of the Brinkman number for single-phase forced convective heat transfer in micro channels," Int. J. Heat Mass Transfer, Vol. 41, pp. 1759–1769.*
27. *Tso, C. P., and Mahulikar, S. P., 1999, "Role of the Brinkman number in analyzing flow transitions in micro channels," Int. J. Heat Mass Transfer, Vol. 42, pp. 1813–1833.*
28. *Tso, C. P., and Mahulikar, S. P., 2000, "Experimental verification of the role of Brinkman number in micro channels using local parameters," Int. J. Heat Mass Transfer, Vol. 43, pp. 1837, 1849.*
29. *Ma, H. B., Peterson, G. P., and Lu, X. J., 1994, "Influence of vapor-liquid interactions on the liquid pressure drop in triangular microgrooves," Int. J. Heat Mass Transfer, Vol. 37, pp. 22112219.*
30. *Kleiner, M. B., Kuehn, S. A., and Haberger, K., 1995, "High performance forced air cooling scheme employing micro channel heat exchangers," IEEE Trans. Components, Packaging, and Manuf. Technol. A Vol. 18, pp. 795–804.*
31. *Takamatsu, K., Fujimoto, N., Rao, Y. F., and Fukuda, K., 1997, "Numerical study of flow and heat transfer of super fluid helium in capillary channels," Cryogenics, Vol. 37, pp. 829–835.*
32. *Copeland, D., Behnia, M., and Nakayama, W., 1997, "Manifold micro channel heat sinks: Isothermal analysis," IEEE Transactions on Components, Packaging, and Manufacturing Technology – Part A, Vol. 20, pp. 96–102.*
33. *Mala, G. M., Li, D., and Dale, J. D., 1997a, "Heat transfer and fluid flow in micro channels," Int. J. Heat Mass Transfer, Vol. 40, pp. 3079–3088.*
34. *Mala, G. M., Li, D., Werner, C., Jacobasch, H. J., and Ning, Y. B., 1997b, "Flow characteristics of water through a micro channel between two parallel plates with electro kinetic effects," Int. J. Heat Fluid Flow, Vol. 18, pp. 489–496.*
35. *Yang, C., Li, D., and Masliyah, J. H., 1998, "Modeling forced liquid convection in rectangular micro channels with electrokinetic effects," Int. J. Heat Mass Transfer, Vol. 41, pp. 4229–4249.*
36. *Bau, H. H., 1998, "Optimization of conduits' shape in micro scale heat exchangers," Int. J. Heat Mass Transfer, Vol. 41, pp. 2717–2723.*
37. *Lee, D. Y. and Vafai, K., 1999, "Comparative analysis of jet impingement and micro channel cooling for high heat flux applications," Int. J Heat Mass Transfer, Vol. 42, pp. 1555–1568.*
38. *Sturgis, J. C., and Mudawar, I., 1999a, "Critical heat flux in a long, rectangular channel subjected to one-sided heating – I. Flow visualization," Int. J. Heat Mass Transfer, Vol. 42, pp. 1835–1847.*
39. *Sturgis, J. C., and Mudawar, I., 1999b, "Critical heat flux in a long, rectangular channel subjected to one-sided heating – II. Analysis of critical heat flux data," Int. J. Heat Mass Transfer, Vol. 42, pp. 1849–1862.*
40. *Cute, J. M., McDonald, C. E., and Shekarriz, A., 1996, "Forced convection heat transfer inparallel channel array micro channel heat exchanger," Advances in Energy Efficiency, Heat/Mass Transfer Enhancement, ASME PID-Vol.2/HTD-Vol. 338, pp. 17–23.*
41. *Ravigururajan, T. S., 1998, "Impact of channel geometry on two-phase flow heat transfer characteristics of refrigerants in microchannel heat exchangers," ASME J. Heat Transfer, V.120, pp. 485–491.*
42. *Triplett, K. A., Ghiaasiaan, S. M., Abdel-Khalik, S. I., and Sadowski, D. L., 1999a, "Gas-liquid two-phase flow in microchannels. Part I: Two-phase flow patterns," Int. J. Multiphase Flow, Vol. 25, pp. 377–394.*

43. *Triplett, K. A., Ghiaasiaan, S. M., Abdel-Khalik, S. I., LeMouel, A., and McCord, B. N., 1999b, "Gas-liquid two-phase flow in microchannels. Part II: Void fraction and pressure drop," Int. J. Multiphase Flow, Vol. 25, pp. 395–410.*

44. *Coleman, J. W. and Garimella, S., 1999, "Characterization of two-phase flow patterns in small diameter round and rectangular tubes," Int. J. Heat Mass Transfer, Vol. 42, pp. 2869–2881.*

45. *Roy, S. K., and Avanik, B. L., 1996, "Very high heat flux micro channel heat exchanger for cooling of semiconductor laser diode arrays," IEEE Trans. Components, Packaging, and Manuf. Technol. Part B: Advanced Packaging, Vol. 19, pp. 444–451.*

46. *Aranyosi, A., Bolle, L. M. R., and Buyse, H. A., 1997, "Compact air-cooled heat sinks for power packages," IEEE Trans. Components, Packaging, and Manuf. Technol. Part A, Vol. 20, pp. 442–451.*

47. *Perret, C., Schaeffer, C., and Boussey, J., 1998, "Micro channel integrated heat sinks in silicon technology," IEEE Industry Applications Society Annual Meeting, Vol. 2, 98CH36242, pp. 1051-1055.*

48. *Gillot, C., Schaeffer, C., and Bricard, A., 1998, "Integrated micro heat sink for power multichip module," IEEE Industry Applications Society Annual Meeting, Vol. 2, 98CH36242, pp. 1046–1050.*

49. *Gillot, C., Meysenc, L., and Schaeffer, C., 1999, "Integrated single and two-phase micro heat sinks under IGBT chips," IEEE Transactions on Components and Packaging Technology, Vol. 22, pp. 384–389.*

50. *Yu, S., Ameel, T., and Xin, M., 1999, "An air-cooled micro channel heat sink with high heat flux and low-pressure drop," Procs. 33rd National Heat Transfer Conference, Albuquerque, New Mexico, Paper No. NHTC 99–162, pp. 1–7.*